

UNIVERSITY OF CONNECTICUT  
DIVISION OF PUBLIC SAFETY

Locksmith Department

January 6, 2006

University of Connecticut Design Guidelines

08 100 STANDARD STEEL DOORS AND FRAMES

1. Dormitory exterior doors should have 14-gauge steel
2. Dormitory exterior door frames should have 12-gauge steel

WE NEED STANDARDS FOR ALUMINUM DOORS

WE NEED TO RESTRICT OR LIMIT DOUBLE DOORS WITHOUT MULLIONS

Double doors without mullions have vertical rod hardware, and they are problematic

08 710 FINISH HARDWARE

24. Cylinders and Locksets

1. Acceptable Manufacturers - Standard Cylinders (construction keyed)
  - A. Sargent
  - B. Schlage Everest
  - C. Best (only for Audio/Video cabinets, and rooms; to be approved.)

Acceptable Manufacturers - Standard Locksets

Sargent Grade 1 Lockset

- A. Sargent 8200 Series
- B. Sargent 11 Line (When approved)
- C. Sargent 10 Line (When approved)

Schlage Grade 1 Lockset

- D. Schlage L Series
- E. Schlage D Series (When approved)

- 2. Keying systems are to be on a Schlage Everest or Sargent Restricted.
- 3. All Mechanical, Electrical, Telephone, Data, and Janitor closets need to be keyed to our existing Sargent Grandmaster key system.
- 4. Supply four keys per Lockset
- 5. Coordinate keying with Owner's, including Uconn Locksmith
- 6. Supply key bitting chart with 150 percent expansion
- 7. Supply complete Hardware Schedule, with keysets, on a Excel spread sheet; on CD or Email

**Note: All keys are to be shipped directly to the Uconn Locksmith Department**

25. Programmable Locks

- 1. Acceptable Manufacturers - Programmable Locks
  - 1. Locknetics CM5596-MGK-17-LC-26D-ATK-HSS
  - 2. Persona (equivalent to above, and approval needed)
  - 3. Sargent

26. Exit Devices

- 1. Acceptable Manufacturers
  - 1. Sargent
  - 2. Von Duprin
- 2. Quality Standard: Heavy Duty Sargent 8800 Series, or Von Duprin 98 and 99 Series.
- 3. Exit devices dogging: All exterior doors with exit devices shall be equipped with a keyed dogging device to hold the push bar down and the latch bolt in the open position. The outside trim is to be night latch function. EXCEPTION: fire rated doors, and electric dogging.
- 8. All exit devices shall be a rim device unless otherwise approved.  
Use mullions with double doors, unless otherwise approved.

January 11, 2006

**NOTE:** Aluminum Doors are to follow University Guidelines for exit devices. With pairs of doors they should have a mullion with Rim Exit Devices, night latch function, and cylinder dogging.

32. Electric Strike

1. Acceptable Manufacturers

1. Folger-Adams 310-4 (for rim exit devices)
2. H.E.S. 9600 (for rim exit devices)
3. Von Duprin 6112 (for rim exit devices)

Paul T. Brazeau, Jr.

Locksmith Supervisor

An Equal Opportunity Employer

25 Ledoyt Road Unit 3167  
Storrs, Connecticut 06269-3167

Telephone: (860) 486-2921

Facsimile: (860) 486-0363