

## **Fire Protection**

- A. Do not use plastic pipe materials above ground.
- B. Hubless cast iron pipe is acceptable above grade (not acceptable below grade).
- C. Provide at least 2 roof drains per section of reel. See Uniform Construction Code for additional requirements.
- D. Minimum cover under roads for Sanitary Sewer Systems shall be 3' 6" and minimum slope shall be 1" in 15' 0" (.55% slope).