

Fire Protection

- A. Shower control valves shall be pressure balance type, solid brass construction.
- B. All plumbing fixtures shall have water saving type controls.
- C. All plumbing fixtures must be tight fitting to walls and be neatly sealed at joint with silicone sealant.
- D. All piping penetrating walls shall be covered with escutcheon plates.
- E. Plumbing fixtures and fittings for laboratory furniture shall be provided by the laboratory furniture manufacturer.
- F. Provide freezeless wall hydrants every 50' on exteriors of new buildings. Model B65 series as made by Woodford Manufacturing, Inc. or approved equal.
- G. The University of Connecticut has standardized toilet and bath fixtures. Provide units as follows:
 - 1. Wall-Mount Toilets Kohler "Kingston" Model
 - 2. Flush valves Sloan Model No. 110-3

All Plumbing work must comply with Public Health Code (PHC) Sections 19-13-B37 and B38. (Fire Sprinkler Regulations Attached).