

## **Fire Protection**

- A. Major water mains shall be ductile iron, double cement lined, mechanical joint with thrust or rod as necessary. Cover exterior pipes per Factory mutual requirements (or minimum 4' 6").
- B. High pressure system covers, hydrants, etc shall be painted "OSHA Orange".