

**10 100 VISUAL DISPLAY BOARDS**

- A. Bottom of cabinet shall be mounted 16" above floor.

**10 160 TOILET PARTITIONS**

- A. Floor mounted partitions shall be used.

**10 440 INTERIOR SIGNAGE**

- A. The scope of work for all projects involving new or existing building interiors work, shall include interior building signage, including all signage required by the building code and by the ADA.
- B. Provide for custom color selection. Do not use fused lettering as it can be easily removed. All plastic shall be self-extinguishing.

**10 522 FIRE EXTINGUISHERS, CABINETS AND ACCESSORIES**

- A. Fire extinguishers shall be provided in accordance with the State Building and Fire Codes. Fire extinguishers shall be multi-purpose dry chemical type, 4A60BC nominal in mechanical rooms; 2A pressurized water type where installed in corridors.
- B. Break-glass faced fire extinguisher cabinets are prohibited. Use solid cabinet, unlocked, with small window made of polycarbonate or other plastic glazing to verify the presence of fire extinguisher in corridors. Use hook mount in non-corridor locations.
- C. When used, bottom of cabinet shall be mounted 16" above floor.

**10 800 TOILET AND BATH ACCESSORIES**

- A. University-Supplied Accessories: the University provides Paper towel and toilet paper dispensers. Drawings and Specifications should provide for installation of these items and any related blocking.
- B. Designers should allow sufficient space for the mounting of University-supplied items. For planning purposes refer to the requirements for the following:
  - 1. Paper Towel Dispensers: Scott Model No. 113, 12" x 15" x 10-1/2" deep.
  - 2. Toilet Paper Dispensers: Standard Canter Model No. R4500, Jumbo Roll Dispenser, 12-1/2" h x 20-1/2" w x 5-5/8" deep.

- C. Project-Supplied Accessories: Soap dispensers, tampon/sanitary napkin dispensers, grab bars, mirrors, utility hooks shower curtains and rods, and handicap shower seats are provided by the project. Drawings and Specifications should provide for the purchase and installation of these items and any related blocking. Acceptable manufacturers for these items are American Specialties, Inc., Bobrick Washroom Equipment, Inc. and McKinney/Parker. Items specified must be similar in operation to the following:
1. Countertop-Mounted Soap Dispensers: Bobrick Model No. B-822.
  2. Wall-Mounted Soap Dispensers: Bobrick Model No. B2111 or B2112, 4-3/4" x 8-1/8" x 5-3/8" deep. Allow a minimum of 4" clearance between the top of the dispenser and the bottom of any shelf cabinet or other projection to provide enough space to fill the dispenser conveniently.
  3. Tampon/Sanitary Napkin Dispensers (if used): Hospital Specialty Dual No. 1 Vendor for napkins and tampons, 10" x 24" x 7-1/4" deep. Twenty-five-cent coin required.
  4. Grab Bars: Bobrick Stainless Steel grab bars with set screw concealed mounting.
  5. Swing-up Grab Bars: Bobrick Model No. B-4998.
  6. Mirrors: Bobrick B-290 Series.
  7. Utility Hooks: Bobrick Model No. B-670.
  8. Shower Curtains: Bobrick 204 Series vinyl shower curtain.
  9. Shower Rods: Bobrick Model No. B-6047.
  10. Handicap Shower Seats: Bobrick Model B-5171 or B-5181.
- D. Custodial Space Requirements
1. General: Custodial closets shall be secured and dedicated strictly for janitorial usage. Do not include any electrical, mechanical or communications functions in these spaces.

- a. Do not position closets so that they are accessed through a restroom. This limits work assignments from a gender standpoint.
  - b. Where multiple closets of the same type are required on the same floor, separate the closets as far as is reasonable. Do not combine them in one space.
2. Wet Closets: Wet closets shall be a minimum of 36 sq. ft. All wet closets shall be equipped with a floor mount wet sink and storage shelving for paper products, cleaning supplies, chemicals and equipment.
- a. Buildings with up to 25,000-sq. ft. per floor: Provide at least one wet closet per floor.
  - b. Buildings with over 25,000-sq. ft. per floor: Provide at least one wet closet per floor for each 25,000 sq. ft.
3. Dry Closets: Dry closets shall be a minimum of 100 sq. ft. All dry closets shall be provided with shelving for back stock storage of paper products, chemicals supplies and cleaning equipment.
- a. Provide at least one dry storage closet for each 50,000-sq. ft. of total building space.